

कार्यालय अग्निशमन अधिकारी, जनपद फतेहगण उ० प्र०

पत्रांक: एक एस / कार्व० /2022 /056

दिनांक:- शितम्बर 19, 2022

सेवा में,

जे० एस० एम० पब्लिक स्कूल
कमालगंज, फर्रुखाबाद

विषय: प्रतिष्ठान / फर्म में स्थापित फायर एक्सटिंग्यूशरों की कार्यशीलता के प्रमाणीकरण के सम्बन्ध में ।
सन्दर्भ: आपके प्रार्थना पत्र संख्या दिनांक 18.09.2022 उपरोक्त संदर्भित विषय आपके प्रार्थना पत्र के क्रम में आपके संस्थान में उपलब्ध 10 अदद फायर एक्सटिंग्यूशरों की टेस्टिंग हेतु शासनादेश संख्या: 1120(1)/आठ, दिनांक 27.12.1982 में दिए गए निर्देशों के अनुसार निर्धारित शुल्क 120.00 रु० भारतीय स्टेट बैंक शाखा कमालगंज, फर्रुखाबाद में घालान संख्या SF30229 दिनांक 19.09.2022 द्वारा जमा कराया गया । प्राप्त रसीद प्राप्त होने के उपरान्त 10 अदद फायर एक्सटिंग्यूशरों का परीक्षण किया गया, जिसका विवरण निम्नवत है ।

क्र०सं०	फायर एक्सटिंग्यूशरों का प्रकार	क्षमता	संख्या	कार्यशीलता / अकार्यशीलता
1	ए0वी0सी0	06 किग्रा0	08 अदद	कार्यशील
2	सी0ओ0टू0	4.5 किग्रा0	02 अदद	कार्यशील
3	मैकेनिकल फोम	09 ली0	03 अदद	कार्यशील
4	फायर वकेटस		06 अदद	कार्यशील

इस प्रकार आपके संस्थान में उपलब्ध फायर एक्सटिंग्यूशरों की कार्यशीलता उपरोक्तानुसार पायी गयी । अतः प्रतिष्ठान में स्थापित फायर एक्सटिंग्यूशरों की कार्यशीलता प्रमाणित की जाती है । शेष सुरक्षा व्यवस्था मानकों के अनुसार वांछनीय होगी तथा समय-समय पर इनकी कार्यशीलता प्रमाणित कराये जाने का उत्तरदायित्व प्रबंधक/स्वामी का होगा ।



Self Attested

प्रभारी अग्निशमन अधिकारी
फायर सेविश
जनपद फतेहगण

Scanned with CamScanner

APPENDIX - XVI

APPENDIX - XII

FIRE SAFETY CERTIFICATE

No. UPFS/2023/Misc-133 / Prov /FGH

Dated: 23/06/2023

Certified that theJSM Public School.....(name of the building or premises) at Kamalganj District Farrukhabad (address) comprised ofZero.....basement(s) and ...two upper floors only ..(ground floor and first floor)..... owned/ occupied byJSM Public School..... (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on19/06/2023.....(date of inspection) in the presence ofMr. Brijendra Pratap Singh (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classesXII th..... (X/ XII) With effect from20/06/2023..... for a period of03..... year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Building height is less than 7 mtrs.
2. Extinguishers and hydrant work is done in the premises, should be kept in working condition and renewed timely.
3. Water storage capacity of the tank should be increased in the future, if required.
- 4.

Issued on ...23/06/2023... (date of Issue) at.....Fatchgarh.....(place) by

*Strike out whichever is not applicable.

Signature with Seal:प्रभारी.....

Name :फतेहगण.....

Designation : Incharge.....C.F.O.....

Name & Address of Department/ Office: CFO Fatehgarh

To

JSM Public School
Kamalganj
Dist.Farrukhabad...U.P.

(Name & Address of the Institution)



Self Attested

Scanned with CamScanner

Scanned with CamScanner